

# TRAC-Cabinet, Ericsson®

Record access of cabinet entry



## Main Features

- Allows single TRACAccess® electronic key access to all shelter and cabinet sites
- Access activity recording for accountability
- Combines electronic access control with mechanical key access for increased security at a low-cost installation

## Overview

TRAC-Cabinet, Ericsson is an electronic access device that records entry into an Ericsson cabinet with an authorized TRACAccess electronic key. The TRAC-Cabinet, Ericsson is powered solely by the TRACAccess key and does not require external wiring or communication networks.

## Features

TRAC-Cabinet, Ericsson is designed with materials that ensure reliability for industrial environments in all weather conditions. It is installed as additional security to the current lock assembly. Minimal cabinet drilling is required. TRAC-Cabinet, Ericsson operates solely from power supplied by the TRACAccess key, requiring no internal batteries or line voltage. The release mechanism is controlled by a microprocessor, requiring a valid TRACAccess key for authorized entry. The electronics are protected from the physical environment and resistant to improper handling or tampering.

## Operation

Remove the interface cover and insert the TRACAccess key into the interface. Insert the KABA key into the door's keyhole and turn to remove the lock core. Then insert the T-tool door handle into the keyhole and operate the TRACAccess key. When the light on the interface turns green, rotate the T-tool door handle and open the cabinet door. To close and lock the cabinet door, operate the TRACAccess key again and rotate the T-tool door handle and close the cabinet door. Then insert and lock the KABA lock core, remove the TRACAccess key from the key interface, and put the cover back in place.

## Product Use



The TRAC-Cabinet, Ericsson is mounted to the cabinet door.



Enter the PIN and place the TRACcess key into the TRAC-Cabinet, Ericsson.



The TRAC-Cabinet, Ericsson unlocks the cabinet door, which can then be opened.

## Specifications

### Environmental

- Operating temperature: -40 to 185°F (-40 to 85°C)
- Humidity: MIL-STD 202F per Method 106D at 95% relative humidity
- Temperature/humidity: MIL-STD 202F, Method 106E at 80% to 95% relative humidity
- Electrostatic discharge: IEC 801-2, Severity Level 3
- Water resistance: UL 1037, section 64 for a one hour rain test
- Dust: SAE J211, 4.5.3 exterior vehicle dust conditions
- Corrosion: MIL-STD 28800D for 48-hour salt fog spray
- Chemical resistance: Resists damage caused by common cleaners and de-icers

## Order Information

- 001735 TRAC-Cabinet, Ericsson Installation Bracket, Contractors, with mounting bracket template
- 001734 TRAC-Cabinet, Ericsson Installation Bracket, Contractors, without mounting bracket template

Supra  
4001 Fairview Industrial Dr. SE  
Salem, OR USA 97302  
T 800-547-0252  
[www.suprasystems.com/traccess](http://www.suprasystems.com/traccess)



Ericsson is a registered trademark of Telefonaktiebolaget LM Ericsson, or its affiliates, in the U.S. and other countries.

© 2013 United Technologies Corporation. All rights reserved.

08/16/2013